

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-08418  
Name of Facility: Broadmoor Elementary  
Address: 3401 NW 83 Street  
City, Zip: Miami 33147  
  
Type: Public School  
Owner: M-DCSB Food and Nutrition  
Person In Charge: Mr. Riaz Phone: (305) 691-0861

**Correct By: Next Inspection  
Re-Inspection Date: None**

**Inspection Information**

Purpose: Routine  
Inspection Date: 3/15/2017

Begin Time: 12:45 PM  
End Time: 01:45 PM

**Additional Information**

FEMALES ..... 180  
MALES ..... 147

CENSUS ..... 327

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	X 15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
X 6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	X 19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

**General Comments**

No General Comments Available

Email Address(es): ipalacio@dadeschools.net;  
omarriaz@dadeschools.net;  
jaybolton@dadeschools.net;  
jware@dadeschools.net

Inspector Signature:

*Thomas A. Opifione*

Client Signature:

*© Waj*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

**Violation #6. Lighting/Foot-Candles**

Replace lights in library storage room 08-004B.

CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

**Violation #15. Handwash Facilities**

Replace paper towels in downstairs boy's restroom 014. \*Fixed on site\*

CODE REFERENCE: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

**Violation #19. Drinking Fountains**

Repair leaking, upstairs water fountain that is currently turned off.

Repair water pressure on two downstairs water fountains near library.

CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Inspection Conducted By: Vanessa Capriglione (115742)  
Inspector Contact Number: Work: (305) 623-3500 ex. 23722  
Print Client Name:  
Date: 3/15/2017

Inspector Signature:

*Vanessa Capriglione*

Client Signature:

*[Handwritten Signature]*